



Customer: Central States Diesel Generators STK#2558
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8174
 Test Date 10-9-19

Engine Make/ Model: Detroit Series 60 4-cycle
 Engine Spec/ Serial: 06R0652320
 Unit Make/ Model: Kohler 250REOZD
 Unit Spec/ Serial: 643294

Voltage: 120/208
 Amperage: 721
 Kilowatts: 260
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	831.1	831.3	831.6	831.8	832.1	832.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	209	208	209	208	209	209
PH2	208	209	208	209	208	208
PH3	209	209	209	209	209	209
Amperage PH1	0	720	721	719	721	0
PH2	0	719	719	720	719	0
PH3	0	720	720	720	720	0
Kilowatts	0	260	260	260	260	0
Oil Pressure	55	51	50	50	50	53
Oil Temperature						
Coolant Temperature	180°F	184°F	184°F	184°F	184°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	28.2	28.2	28.2	28.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	66°F	66°F	66°F	66°F	67°F	67°F

Technician Signature: Randy Pool

Customer Signature: _____