



Customer: Central States Diesel Generators STK#2559
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8270
 Test Date 11-8-19

Engine Make/ Model: Cummins LTA-10G1
 Engine Spec/ Serial: 34867409
 Unit Make/ Model: Cummins 230DFAB
 Unit Spec/ Serial: F970641700

Voltage: 277/480
 Amperage: 346
 Kilowatts: 230
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	534.1	534.3	534.6	534.8	535.1	535.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	481	480	480	480
PH2	481	481	482	481	482	481
PH3	481	482	482	482	481	481
Amperage PH1	0	240	240	240	240	0
PH2	0	241	241	241	241	0
PH3	0	240	240	241	241	0
Kilowatts	0	300	200	200	200	0
Oil Pressure	42	38	34	34	34	36
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	33°F	33°F	34°F	34°F	34°F	34°F

Technician Signature: _____

Customer Signature: _____