



Customer: Central States Diesel Generators STK#2564  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8269  
 Test Date 11-1-19

Engine Make/ Model: Cummins NTA-855-G2  
 Engine Spec/ Serial: 30363604  
 Unit Make/ Model: Cummins DFCB-3381438  
 Unit Spec/ Serial: K990026648

Voltage: 120/208  
 Amperage: 833  
 Kilowatts: 300  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	123.6	123.9	124.1	124.4	124.6	124.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	208	208	208	208	208
PH3	208	208	208	208	208	208
Amperage PH1	0	833	833	832	833	0
PH2	0	833	833	833	833	0
PH3	0	834	834	833	833	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	62	56	55	55	55	58
Oil Temperature						
Coolant Temperature	178°F	179°F	180°F	180°F	180°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	33°F	33°F	33°F	33°F	33°F	34°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_