



Customer: Central States Diesel Generators STK#2565
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 8433
 Test Date 11-26-2019

Engine Make/ Model: Cummins QSX15-G9
 Engine Spec/ Serial: 79892573
 Unit Make/ Model: Cummins DFEK-A045B571
 Unit Spec/ Serial: L150905894

Voltage: 277/480
 Amperage: 752
 Kilowatts: 500
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	59	59.2	59.5	59.7	60	60.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	479	479	479	479	480
PH3	480	480	480	480	480	480
Amperage PH1	0	603	602	603	602	0
PH2	0	601	602	602	603	0
PH3	0	602	603	602	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	44	41	40	40	40	42
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	33°F	33°F	33°F	34°F	34°F	34°F

Technician Signature: Randy Pool

Customer Signature: _____