



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 8478
 Test Date 2019.12.05

Engine Make/ Model: John Deere 6068TF250
 Engine Spec/ Serial: PE6068T538688
 Unit Make/ Model: Kohler 100REOZJB
 Unit Spec/ Serial: S/N: 2085164 Spec: GM31029-GA3

Voltage: 480
 Amperage: 165
 Kilowatts: 110
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	366		367			367
Hertz/Cycles	60	60	60			60
Voltage PH1	480	479	478			480
PH2	482	480	480			482
PH3	483	483	483			483
Amperage PH1	66	130	130			0
PH2	66	130	130			0
PH3	66	130	130			0
Kilowatts	55	108	108	0	0	0
Oil Pressure	55	50	50			
Oil Temperature						
Coolant Temperature	170°F	180°F	185°F			176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature	366°F	580°F	580°F			
DC Voltage	14	14	14			14
Natural Gas Pressure						
Diesel Fuel Level	50	50	50			50
Room Temperature						
Ambient Temperature	25°F	25°F	25°F			25°F

Technician Signature: Matt Czaplicki

Customer Signature: _____