



Customer: Central States Diesel Generators STK#2576
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-995-7655

R#: 9648
 Test Date 8-10-2020

Engine Make/ Model: MTU Detroit Diesel Series 60
 Engine Spec/ Serial: 06R0513436
 Unit Make/ Model: Kohler 300REOZDN
 Unit Spec/ Serial: PA-194400-R 0639325

Voltage: 277/480 (Multiselect)
 Amperage: 361
 Kilowatts: 300
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	3526.4	3536.6	3536.9	3537.1	3537.4	3537.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	477	478	478	477	480
PH2	481	479	479	479	479	481
PH3	480	478	478	477	477	480
Amperage PH1	0	363	362	363	363	0
PH2	0	362	363	363	362	0
PH3	0	363	363	362	363	0
Kilowatts	0	300	300	300	300	0
Oil Pressure	68	62	60	60	60	64
Oil Temperature	190°F	212°F	212°F	213°F	213°F	190°F
Coolant Temperature	172°F	176°F	176°F	176°F	176°F	173°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	82°F	82°F	83°F	83°F	83°F	83°F

Technician Signature: Randy Pool

Customer Signature: _____