



Customer: Central States Diesel Generators STK#2577
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: DALE
 Test Date 11-1-19

Engine Make/ Model: Caterpillar 3412
 Engine Spec/ Serial: 81Z01302
 Unit Make/ Model: Caterpillar 3412
 Unit Spec/ Serial: 81Z01302

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	714	714	714	714	715	715
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	481	482	481	482	0
PH2	0	480	480	480	480	0
PH3	0	482	481	482	481	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	Normal	Normal	Normal	Normal	Normal	Normal
Oil Temperature						
Coolant Temperature	Normal	Normal	Normal	Normal	Normal	Normal
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	35°F	35°F	34°F	34°F	34°F

Technician Signature: _____

Customer Signature: _____