



Customer: Central States Diesel Generators STK#2578
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8369
 Test Date 11-14-19

Engine Make/ Model: Cummins NT-855 G/5
 Engine Spec/ Serial: 11593876
 Unit Make/ Model: Cummins250DFBE 37981E
 Unit Spec/ Serial: F900328406

Voltage: 277/480
 Amperage: 376
 Kilowatts: 250
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	244	244.2	244.5	244.7	245	245.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	480	481	480	480	481
PH2	480	480	481	480	480	480
PH3	482	482	482	482	482	482
Amperage PH1	0	300	302	301	302	0
PH2	0	299	300	301	301	0
PH3	0	300	299	300	299	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	65	60	55	55	55	56
Oil Temperature						
Coolant Temperature	170°F	172°F	172°F	172°F	172°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.5	28.5	28.5	28.5	28.5	28.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	21°F	21°F	21°F	21°F	22°F	22°F

Technician Signature: Randy Pool

Customer Signature: _____