



Customer: Central States Diesel Generators STK#2579
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8558
 Test Date 3-19-20

Engine Make/ Model: MTU 12V2000
 Engine Spec/ Serial: 5352004319
 Unit Make/ Model: Kohler 750REOZDB
 Unit Spec/ Serial: 2079398

Voltage: 277/480
 Amperage: 902
 Kilowatts: 750
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	340	340.2	340.5	340.7	341	341.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	903	902	903	901	0
PH2	0	901	902	901	902	0
PH3	0	902	902	902	903	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	125	110	110	110	110	113
Oil Temperature						
Coolant Temperature	170°F	170°F	170°F	170°F	170°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	37°F	37°F	37°F	37°F	38°F	38°F

Technician Signature: Randy Pool

Customer Signature: _____