

Customer: Central States Diesel Generators STK#2583
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8724
 Test Date 1-30-20

Engine Make/ Model: Doosan D34PP
 Engine Spec/ Serial: 7032453
 Unit Make/ Model: Doosan G70WDO-3A-T4F
 Unit Spec/ Serial: 484728UCACG14

Voltage: 277/480 Multi-select
 Amperage: 67
 Kilowatts: 56
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	60 Min.	75 Min.	90 Min.	105 Min.	120 Min.	COOLDOWN
Eng Hours	550	550.3	550.5	550.8	551	551.3	551.5	551.8	552	552.1
Hertz/Cycles	60	60	60	60	60	60	60	60	60	60
Voltage PH1	488	488	488	488	488	488	488	488	488	488
PH2	487	487	487	487	487	487	487	488	487	487
PH3	487	486	487	486	486	486	486	487	486	487
Amperage PH1	0	22	44	66	66	66	66	66	66	0
PH2	0	22	44	67	66	66	66	67	66	0
PH3	0	22	44	67	66	66	66	67	66	0
Kilowatts	0	19	37	56	56	56	56	56	56	0
Oil Pressure	87	82	81	81	81	81	81	81	81	82
Oil Temperature	200°F	204°F	206°F	208°F	208°F	208°F	208°F	208°F	208°F	200°F
Coolant Temperature	175°F	179°F	179°F	180°F	180°F	180°F	180°F	180°F	180°F	178°F
Man Vac./Press. L/B										
Man Vac./Press. R/B										
L/B Exhaust Temp										
R/B Exhaust Temp										
Exhaust Temperature										
DC Voltage	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4	14.4
Natural Gas Pressure										
Diesel Fuel Level										
Room Temperature										
Ambient Temperature	26°F	26°F	27°F	27°F	27°F	27°F	28°F	28°F	28°F	29°F

Technician Signature: Randy Pool

Customer Signature: _____