



Customer: Central States Diesel Generators STK#2584
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8434
 Test Date 12-3-19

Engine Make/ Model: Volvo TAD1242GE
 Engine Spec/ Serial: 2012497282
 Unit Make/ Model: Kohler 400REOZV
 Unit Spec/ Serial: 2053339

Voltage: 277/480
 Amperage: 601
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	503	503.2	503.5	503.7	504	504.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	480	479	480
PH2	481	480	481	481	480	481
PH3	481	481	481	481	481	481
Amperage PH1	0	481	480	481	481	0
PH2	0	480	481	482	481	0
PH3	0	480	481	481	482	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	65	58	54	53	53	56
Oil Temperature						
Coolant Temperature	185°F	194°F	195°F	195°F	195°F	188°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	36°F	36°F	36°F	36°F	36°F	36°F

Technician Signature: Randy Pool

Customer Signature: _____