



Customer: Central States Diesel Generators STK#2592
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8485
 Test Date 12-3-19

Engine Make/ Model: Ford LSG-875I-6005-A
 Engine Spec/ Serial: A-05-RA 04880
 Unit Make/ Model: Kohler 60RZ272
 Unit Spec/ Serial: 356557

Voltage: 277/480
 Amperage: 91
 Kilowatts: 60
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1554.8	1555.1	1555.3	1555.6	1555.8	1555.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	481	480	480	479	480
PH2	480	480	480	481	480	480
PH3	481	481	481	481	481	481
Amperage PH1	0	0	0	0	0	0
PH2	0	0	0	0	0	0
PH3	0	0	0	0	0	0
Kilowatts	0	0	0	0	0	0
Oil Pressure	75	71	70	70	70	71
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	36°F	36°F	36°F	36°F	36°F	36°F

Technician Signature: Randy Pool

Customer Signature: _____