



Customer: Central States Diesel Generators STK#2594  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8556  
 Test Date 1-9-20

Engine Make/ Model: MTU 6R1600G70S  
 Engine Spec/ Serial: 16301001314  
 Unit Make/ Model: MTU DS250  
 Unit Spec/ Serial: 331331-1-1-0311

Voltage: 277/480  
 Amperage: 376  
 Kilowatts: 250  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	293.4	293.6	293.9	294.1	294.4	291.5
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	301	301	301	302	0
PH2	0	300	301	302	301	0
PH3	0	302	301	301	301	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	75	74	73	73	73	74
Oil Temperature						
Coolant Temperature	155°F	157°F	157°F	157°F	157°F	155°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.8	27.8	27.8	27.8	27.8	27.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	35°F	35°F	35°F	35°F	35°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_