



Customer: Central States Diesel Generators STK#2595  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8555  
 Test Date 1-6-20

Engine Make/ Model: Fiat F4GE9685A  
 Engine Spec/ Serial: J602-01572323  
 Unit Make/ Model: Generac SD0130GG176.7D18HPSY3  
 Unit Spec/ Serial: 3003092091

Voltage: 120/208  
 Amperage: 452  
 Kilowatts: 130  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	30.2	30.5	30.7	31	31.2	31.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	208	208	208	208	208	208
PH3	208	208	208	208	208	208
Amperage PH1	0	361	361	361	361	0
PH2	0	362	360	360	361	0
PH3	0	361	362	360	360	0
Kilowatts	0	130	130	130	130	0
Oil Pressure	55	51	50	50	50	51
Oil Temperature						
Coolant Temperature	175°F	178°F	178°F	178°F	178°F	177°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.5	14.5	14.5	14.5	14.5	14.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	29°F	29°F	29°F	30°F	30°F	30°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_