



Customer: Central States Diesel Generators STK# 2596
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8521
 Test Date 12-16-19

Engine Make/ Model: Volvo Penta TAD1031GE
 Engine Spec/ Serial: 210033
 Unit Make/ Model: Kohler 250REOZV
 Unit Spec/ Serial: GM24720-GA3 2018091

Voltage: 277/480
 Amperage: 313
 Kilowatts: 260
 Power Factor 0.8

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 295.3 | 295.5 | 295.8 | 296 | 296.3 | 296.4 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 480 | 480 | 480 | 480 | 480 | 480 |
| PH2 | 479 | 479 | 479 | 479 | 479 | 479 |
| PH3 | 479 | 479 | 479 | 479 | 479 | 479 |
| Amperage PH1 | 0 | 313 | 314 | 313 | 314 | 0 |
| PH2 | 0 | 312 | 313 | 314 | 313 | 0 |
| PH3 | 0 | 314 | 312 | 312 | 312 | 0 |
| Kilowatts | 0 | 260 | 260 | 260 | 260 | 0 |
| Oil Pressure | 80 | 76 | 76 | 76 | 76 | 76 |
| Oil Temperature | | | | | | |
| Coolant Temperature | 170°F | 173°F | 173°F | 173°F | 173°F | 172°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 28.1 | 28.1 | 28.1 | 28.1 | 28.1 | 28.1 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 22°F | 22°F | 23°F | 23°F | 23°F | 23°F |

Technician Signature: Randy Pool

Customer Signature: _____