



Customer: Central States Diesel Generators STK#2597  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8522  
 Test Date 12-23-19

Engine Make/ Model: Caterpillar 3512C  
 Engine Spec/ Serial: 8RM00583  
 Unit Make/ Model: Caterpillar 3512C  
 Unit Spec/ Serial: SBG00562

Voltage: 277/480  
 Amperage: 2255  
 Kilowatts: 1500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	191	191.2	191.5	191.7	192	192.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	488	488	488	488	488	488
PH2	487	487	488	487	487	487
PH3	488	487	488	488	487	488
Amperage PH1	0	1778	1776	1779	1778	0
PH2	0	1777	1778	1778	1779	0
PH3	0	1776	1776	1777	1779	0
Kilowatts	0	1500	1500	1500	1500	0
Oil Pressure	70	63	61	61	61	63
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	181°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	24.7	24.7	24.7	24.7	24.7	24.7
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	41°F	41°F	42°F	42°F	43°F	43°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_