



Customer: Central States Diesel Generators STK#2598

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 8520

Test Date 12-23-19

Engine Make/ Model: Caterpillar 3412

Engine Spec/ Serial: BLGO0318

Unit Make/ Model: Caterpillar 3412

Unit Spec/ Serial: CAT00000KBCW00387

Voltage: 277/480

Amperage: 902

Kilowatts: 750

Power Factor 0.8

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 522 | 522 | 522 | 522 | 523 | 523 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 480 | 479 | 479 | 479 | 479 | 480 |
| PH2 | 479 | 479 | 479 | 479 | 479 | 479 |
| PH3 | 480 | 480 | 480 | 480 | 480 | 480 |
| Amperage PH1 | 0 | 906 | 906 | 905 | 904 | 0 |
| PH2 | 0 | 905 | 904 | 906 | 905 | 0 |
| PH3 | 0 | 904 | 904 | 903 | 903 | 0 |
| Kilowatts | 0 | 750 | 750 | 750 | 750 | 0 |
| Oil Pressure | 64 | 61 | 61 | 61 | 61 | 62 |
| Oil Temperature | 195°F | 203°F | 203°F | 203°F | 203°F | 200°F |
| Coolant Temperature | 180°F | 181°F | 181°F | 181°F | 181°F | 180°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 26 | 26 | 26 | 26 | 26 | 26 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 44°F | 44°F | 45°F | 45°F | 45°F | 45°F |

Technician Signature: Randy Pool

Customer Signature: _____