



Customer: Central States Diesel Generators STK#2600
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8554
 Test Date 1-6-20

Engine Make/ Model: Volvo Penta TWD1672GE
 Engine Spec/ Serial: 2016117048
 Unit Make/ Model: Gillette T4D-5500
 Unit Spec/ Serial: PI-27-300

Voltage: 277/480
 Amperage: 828
 Kilowatts: 550
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	26.2	26.5	26.7	27	27.2	27.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	482	482	482	482	482	482
PH3	482	482	482	482	482	482
Amperage PH1	0	661	660	660	661	0
PH2	0	660	661	659	658	0
PH3	0	661	660	661	660	0
Kilowatts	0	550	550	550	550	0
Oil Pressure	68	64	63	63	63	65
Oil Temperature	190°F	210°F	210°F	210°F	210°F	200°F
Coolant Temperature	180°F	181°F	181°F	181°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.1	28.1	28.1	28.1	28.1	28.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	27°F	27°F	27°F	28°F	28°F	28°F

Technician Signature: Randy Pool

Customer Signature: _____