



Customer: Central States Diesel Generators STK#2601

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 8557

Test Date 1-9-20

Engine Make/ Model: MTU 12V2000

Engine Spec/ Serial: 5352000670

Unit Make/ Model: Kohler 750ROZO4

Unit Spec/ Serial: 661572

Voltage: 277/480

Amperage: 842

Kilowatts: 700

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	186.8	187.1	187.3	187.6	187.8	187.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	483	483	483	482	483	483
PH2	482	482	482	482	482	482
PH3	483	483	483	483	483	483
Amperage PH1	0	838	838	838	838	0
PH2	0	839	838	839	839	0
PH3	0	838	839	838	838	0
Kilowatts	0	700	700	700	700	0
Oil Pressure	145	123	121	121	121	124
Oil Temperature						
Coolant Temperature	180°F	191°F	192°F	192°F	192°F	186°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	34°F	34°F	35°F	35°F	35°F	35°F

Technician Signature: Randy Pool

Customer Signature: _____