



Customer: Central States Diesel Generators STK#2602
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8585
 Test Date 5-29-20

Engine Make/ Model: Mitsubishi S12A2-Y2PTAW-2
 Engine Spec/ Serial: 25876
 Unit Make/ Model: Baldor IDLC800-2M
 Unit Spec/ Serial: P0902240004

Voltage: 277/480
 Amperage: 962
 Kilowatts: 800
 Power Factor 0.8

| | 5 Min. | 15 Min. | 30 Min. | 45 Min. | 1 Hour | Cool Down |
|----------------------|--------|---------|---------|---------|--------|-----------|
| Eng Hours | 29 | 29 | 29 | 29 | 29 | 30 |
| Hertz/Cycles | 60 | 60 | 60 | 60 | 60 | 60 |
| Voltage PH1 | 480 | 481 | 480 | 481 | 481 | 480 |
| PH2 | 481 | 481 | 481 | 481 | 481 | 481 |
| PH3 | 480 | 480 | 481 | 481 | 480 | 480 |
| Amperage PH1 | 0 | 964 | 962 | 962 | 962 | 0 |
| PH2 | 0 | 962 | 961 | 962 | 963 | 0 |
| PH3 | 0 | 963 | 963 | 961 | 962 | 0 |
| Kilowatts | 0 | 800 | 800 | 800 | 800 | 0 |
| Oil Pressure | 66 | 61 | 59 | 58 | 58 | 0 |
| Oil Temperature | | | | | | |
| Coolant Temperature | 160°F | 165°F | 165°F | 165°F | 165°F | 164°F |
| Man Vac./Press. L/B | | | | | | |
| Man Vac./Press. R/B | | | | | | |
| L/B Exhaust Temp | | | | | | |
| R/B Exhaust Temp | | | | | | |
| Exhaust Temperature | | | | | | |
| DC Voltage | 28.4 | 28.4 | 28.4 | 28.4 | 28.4 | 28.4 |
| Natural Gas Pressure | | | | | | |
| Diesel Fuel Level | | | | | | |
| Room Temperature | | | | | | |
| Ambient Temperature | 71°F | 71°F | 71°F | 72°F | 72°F | 72°F |

Technician Signature: _____

Customer Signature: _____