



Customer: Central States Diesel Generators  
 Address: 2001 S. Pairie Ave  
 City/ State/ Zip: Waukesha, WI. 53188  
 Contact: Patrick Paden  
 Phone: 1-847-997-8090

R#: 8582  
 Test Date 1/3/2020  
 CSDG UNIT NO. 2603

Engine Make/ Model: John Deere 6068HFE75  
 Engine Spec/ Serial: PE6068I113642  
 Unit Make/ Model: Baldor TS250T  
 Unit Spec/ Serial: P1003310005

Voltage: 480  
 Amperage: 301 / 241  
 Kilowatts: 200  
 Power Factor .8 PF / 1.0 PF

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour
Eng Hours	128	128.3	128.5	128.8	129
Hertz/Cycles	60	60	60	60	60
Voltage PH1	480	480	480	479	480
PH2	479	479	479	479	479
PH3	481	481	481	481	481
Amperage PH1	230	240	240	240	240
PH2	230	248	240	240	240
PH3	230	240	240	240	240
Kilowatts	191	202	199	199	199
Oil Pressure	53	53	53	53	53
Oil Temperature	N/A	N/A	N/A	N/A	N/A
Coolant Temperature	177°F	177°F	177°F	177°F	177°F
L/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A
R/B Exhaust Temp	N/A	N/A	N/A	N/A	N/A
Exhaust Temperature	N/A	N/A	N/A	N/A	N/A
DC Voltage	13.3	13.3	13.3	13.3	13.3
Natural Gas Pressure	N/A	N/A	N/A	N/A	N/A
Diesel Fuel Level	25	25	25	25	25
Room Temperature	N/A	N/A	N/A	N/A	N/A
Ambient Temperature	38°F	38°F	38°F	38°F	38°F

Cable Length: 5' Cable/ Leg: 1 per leg Connection Point: Breaker

Technician Signature: Matt Czaplinski

Customer Signature: \_\_\_\_\_