



Customer: Central States Diesel Generators STK#2604
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8722
 Test Date 1-30-20

Engine Make/ Model: Cummins NTA-855-G6
 Engine Spec/ Serial: 30367090
 Unit Make/ Model: Cummins DFCE-5003456
 Unit Spec/ Serial: J010301146

Voltage: 277/480
 Amperage: 481
 Kilowatts: 400
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	494.8	495	495.3	495.5	495.8	495.9
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	484	484	484	484	484	484
PH2	483	483	483	483	483	483
PH3	484	484	484	484	484	484
Amperage PH1	0	478	478	477	478	0
PH2	0	478	477	478	477	0
PH3	0	477	479	478	479	0
Kilowatts	0	400	400	400	400	0
Oil Pressure	41	38	36	36	36	37
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	181°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	30°F	30°F	30 Min.	30°F	30°F	30°F

Technician Signature: Randy Pool

Customer Signature: _____