



Customer: Central States Diesel Generators STK#2607
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8586
 Test Date 1-6-20

Engine Make/ Model: Caterpillar C6.6
 Engine Spec/ Serial: E6M01774
 Unit Make/ Model: Caterpillar D125-6
 Unit Spec/ Serial: N6D01449

Voltage: 120/208
 Amperage: 433
 Kilowatts: 125
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	129.5	129.8	130	130.3	130.5	130.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	210	210	210	210	210	210
PH2	210	210	210	211	210	210
PH3	210	211	210	210	211	210
Amperage PH1	0	345	346	345	344	0
PH2	0	345	345	343	345	0
PH3	0	346	344	346	344	0
Kilowatts	0	125	125	125	125	0
Oil Pressure	65	62	61	61	60	61
Oil Temperature						
Coolant Temperature	170°F	174°F	175°F	174°F	175°F	173°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	34°F	34°F	34°F	35°F	35°F	35°F

Technician Signature: Randy Pool

Customer Signature: _____