



Customer: Central States Diesel Generators STK#2613  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8584  
 Test Date 1-30-20

Engine Make/ Model: Caterpillar 3408  
 Engine Spec/ Serial: 78Z01504  
 Unit Make/ Model: Caterpillar 3408  
 Unit Spec/ Serial: 78Z01504

Voltage: 277/480  
 Amperage: 421  
 Kilowatts: 350  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	198.9	199.1	199.4	199.6	199.9	200
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	491	491	491	491	491	491
PH2	491	491	491	491	491	491
PH3	491	491	491	491	491	491
Amperage PH1	0	412	411	412	411	0
PH2	0	413	414	411	412	0
PH3	0	412	412	412	413	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	80	77	75	75	75	76
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	181°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	25.5	25.5	25.5	25.5	25.5	25.5
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	26°F	26°F	26°F	26°F	26°F	26°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_