



Customer: Central States Diesel Generators STK#2614
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8646
 Test Date 2-21-20

Engine Make/ Model: Cummins NTA-855-G3
 Engine Spec/ Serial: 30364704
 Unit Make/ Model: Cummins DFCC-4485955
 Unit Spec/ Serial: H000140182

Voltage: 277/480
 Amperage: 421
 Kilowatts: 350
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	207.9	208.1	208.4	208.6	208.9	209
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	485	484	485	485	485	485
PH2	484	484	484	484	484	484
PH3	484	485	484	484	484	484
Amperage PH1	0	418	418	417	418	0
PH2	0	417	418	418	417	0
PH3	0	418	417	417	418	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	58	50	49	49	49	52
Oil Temperature						
Coolant Temperature	175°F	178°F	178°F	178°F	178°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	31°F	31°F	31°F	31°F	31°F	31°F

Technician Signature: _____

Customer Signature: _____