



Customer: Central States Diesel Generators STK#2615  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 8767  
 Test Date 2-7-2020

Engine Make/ Model: Cummins QST30-G3  
 Engine Spec/ Serial: 37199471  
 Unit Make/ Model: Cummins DFHC-4962461  
 Unit Spec/ Serial: H010267535

Voltage: 120/208  
 Amperage: 2498  
 Kilowatts: 900  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	821	821.2	821.5	821.7	822	822.1
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	208	208	208	208
PH2	207	207	207	208	207	207
PH3	208	208	208	208	208	208
Amperage PH1	0	2507	2507	2502	2507	0
PH2	0	2505	2504	2503	2505	0
PH3	0	2503	2505	2501	2503	0
Kilowatts	0	900	900	900	900	0
Oil Pressure	60	56	55	54	54	55
Oil Temperature						
Coolant Temperature	180°F	184°F	184°F	184°F	184°F	183°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.2	27.2	27.2	27.2	27.2	27.2
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	34°F	34°F	34°F	35°F	35°F	35°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_