



Customer: Central States Diesel Generators STK#2616  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8720  
 Test Date 1-29-20

Engine Make/ Model: Cummins NTA-855-G3  
 Engine Spec/ Serial: 30370055  
 Unit Make/ Model: Cummins DFCC-5629256  
 Unit Spec/ Serial: H030537643

Voltage: 277/480  
 Amperage: 421  
 Kilowatts: 350  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	409.9	410.1	410.4	410.6	410.9	411
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	482	482	482	482	482	482
PH3	482	482	482	482	482	482
Amperage PH1	0	421	420	421	420	0
PH2	0	420	421	420	420	0
PH3	0	420	420	420	421	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	56	53	52	51	51	53
Oil Temperature						
Coolant Temperature	178°F	180°F	180°F	180°F	180°F	179°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	26°F	26°F	26°F	26°F	27°F	27°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_