



Customer: Central States Diesel Generators STK#2617

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 8757

Test Date 2-13-20

Engine Make/ Model: Caterpillar 3412

Engine Spec/ Serial: 81Z24539

Unit Make/ Model: Caterpillar 3412

Unit Spec/ Serial: 81Z24539

Voltage: 277/480

Amperage: 752

Kilowatts: 500

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	554	554	555	555	555	555
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	479	479	479	479	479	479
PH3	480	480	480	480	480	480
Amperage PH1	0	601	601	601	602	0
PH2	0	603	602	603	603	0
PH3	0	602	603	602	603	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	79	77	75	74	74	75
Oil Temperature						
Coolant Temperature	175°F	175°F	175°F	175°F	175°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	10°F	10°F	10°F	10°F	10°F	10°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_