



Customer: Central States Diesel Generators STK#2618  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8797  
 Test Date 2-21-20

Engine Make/ Model: Perkins 1300  
 Engine Spec/ Serial: WS4486N1210580  
 Unit Make/ Model: Caterpillar D200  
 Unit Spec/ Serial: E7542A/001

Voltage: 277/480  
 Amperage: 241  
 Kilowatts: 200  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	285.6	285.8	286.1	286.3	286.6	286.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	479	479	479	479	479	479
PH2	478	478	479	478	478	478
PH3	479	478	478	478	479	479
Amperage PH1	0	242	242	241	242	0
PH2	0	241	241	242	241	0
PH3	0	242	242	242	241	0
Kilowatts	0	200	200	200	200	0
Oil Pressure	65	60	58	58	58	60
Oil Temperature						
Coolant Temperature	185°F	190°F	192°F	192°F	192°F	187°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.6	27.6	27.6	27.6	27.6	27.6
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	26°F	26°F	26°F	27°F	27°F	27°F

Technician Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_