



Customer: Central States Diesel Generators STK#2627  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#: 8780  
 Test Date 2-11-2020

Engine Make/ Model: MTU 6R1600G70S  
 Engine Spec/ Serial: 2013746568  
 Unit Make/ Model: Blue Star Power Systems TD250  
 Unit Spec/ Serial: 105394-1-1

Voltage: 277/480  
 Amperage: 301  
 Kilowatts: 250  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	24.9	25.1	25.4	25.6	25.9	26
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	478	478	478	479	478	478
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	302	302	302	302	0
PH2	0	301	301	300	300	0
PH3	0	300	300	300	301	0
Kilowatts	0	250	250	250	250	0
Oil Pressure	98	90	89	89	88	89
Oil Temperature						
Coolant Temperature	175°F	181°F	181°F	181°F	181°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.9	27.9	27.9	27.9	27.9	27.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	24°F	24°F	24°F	24°F	24°F	24°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_