



Customer: Central States Diesel Generators STK#2628  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8727  
 Test Date 2-3-20

Engine Make/ Model: Cummins QSX15-G9 NR2  
 Engine Spec/ Serial: 79022769  
 Unit Make/ Model: Cummins DFEK-5633015  
 Unit Spec/ Serial: J030558101

Voltage: 277/480  
 Amperage: 602  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	248	248	249	249	249	249
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	482	482	482	482	482	482
PH3	482	482	482	482	482	482
Amperage PH1	0	600	601	600	601	0
PH2	0	599	600	601	599	0
PH3	0	601	600	600	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	45	42	41	41	41	42
Oil Temperature						
Coolant Temperature	180°F	182°F	182°F	182°F	182°F	181°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27.4	27.4	27.4	27.4	27.4	27.4
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	41°F	41°F	41°F	41°F	42°F	42°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_