



Customer: Central States Diesel Generators STK#2630  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8781  
 Test Date 2-12-20

Engine Make/ Model: Caterpillar 3412  
 Engine Spec/ Serial: 81Z20234  
 Unit Make/ Model: Caterpillar 3412  
 Unit Spec/ Serial: 81Z20234

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	751	751	751	751	752	752
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	480	480
PH2	481	481	480	481	481	481
PH3	480	480	480	480	480	480
Amperage PH1	0	602	602	602	603	0
PH2	0	601	601	601	601	0
PH3	0	602	602	602	602	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	82	76	74	74	74	77
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	20°F	20°F	20°F	21°F	21°F	21°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_