



Customer: Central States Diesel Generators STK#2632  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8872  
 Test Date 3-10-20

Engine Make/ Model: Cummins KTA19-G4  
 Engine Spec/ Serial: 37187899  
 Unit Make/ Model: Cummins DFED-3374405  
 Unit Spec/ Serial: F990940437

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	413.5	413.7	414	414.2	414.5	414.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	481	481	481	481	481	481
PH3	481	481	481	481	481	481
Amperage PH1	0	602	602	601	602	0
PH2	0	601	601	602	601	0
PH3	0	602	601	601	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	77	73	71	71	71	72
Oil Temperature						
Coolant Temperature	180°F	181°F	181°F	181°F	181°F	180°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	33°F	33°F	33°F	33°F	34°F	34°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_