



Customer: Central States Diesel Generators STK#2633

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 8871

Test Date 3-20-20

Engine Make/ Model: Caterpillar 3412

Engine Spec/ Serial: 2WJ05884

Unit Make/ Model: Caterpillar 3412

Unit Spec/ Serial: 2WJ05884

Voltage: 277/480

Amperage: 903

Kilowatts: 750

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	1036	1036	1036	1037	1037	1037
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	484	484	484	484	484	484
PH2	482	482	482	482	482	482
PH3	483	483	483	483	483	483
Amperage PH1	0	898	898	898	897	0
PH2	0	897	896	897	897	0
PH3	0	897	898	897	898	0
Kilowatts	0	750	750	750	750	0
Oil Pressure	77	72	67	63	62	65
Oil Temperature						
Coolant Temperature	175°F	176°F	176°F	176°F	176°F	175°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	27	27	27	27	27	27
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	36°F	36°F	37°F	37°F	37°F	37°F

Technician Signature: Randy Pool

Customer Signature: _____