



Customer: Central States Diesel Generators STK#2637
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8902
 Test Date 3-10-20

Engine Make/ Model: John Deere 6059TF
 Engine Spec/ Serial: CD6059T288741
 Unit Make/ Model: Kohler 100ROZJ71
 Unit Spec/ Serial: 384842

Voltage: 277/480 (Multi-Select)
 Amperage: 121
 Kilowatts: 100
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	3280.6	3280.8	3281.1	3281.3	3281.6	3281.7
Hertz/Cycles		60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	480	480	480	480	480	480
PH3	481	481	481	481	481	481
Amperage PH1	0	120	121	120	121	0
PH2	0	120	120	121	120	0
PH3	0	121	120	120	120	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	50	44	42	41	41	45
Oil Temperature						
Coolant Temperature	175°F	178°F	178°F	178°F	178°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	15	15 Min.	15	15	15	15
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	35°F	35°F	35°F	35°F	36°F	36°F

Technician Signature: Randy Pool

Customer Signature: _____