



Customer: Central States Diesel Generators STK#2638  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 8901  
 Test Date 3-10-20

Engine Make/ Model: Cummins 4B3.9-G2  
 Engine Spec/ Serial: 46142406  
 Unit Make/ Model: Cummins DGBB-5002053  
 Unit Spec/ Serial: I010288131

Voltage: 120/240  
 Amperage: 146  
 Kilowatts: 35  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	951.3	951.5	951.8	952	952.3	952.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	244	244	244	244	244	244
PH2	122	122	122	122	122	122
PH3	122	122	122	122	122	122
Amperage PH1	0	145	144	145	144	0
PH2	0	144	145	144	145	0
PH3	0	0	0	0	0	0
Kilowatts	0	35	35	35	35	0
Oil Pressure	65	60	58	58	58	60
Oil Temperature						
Coolant Temperature	180°F	185°F	185°F	185°F	185°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	33°F	33°F	33°F	33°F	34°F	34°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_