



Customer: Central States Diesel Generators STK#2640
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 8946
 Test Date 3-25-20

Engine Make/ Model: GM 5.7L
 Engine Spec/ Serial: 5P7L09751
 Unit Make/ Model: Kohler 60RZG
 Unit Spec/ Serial: 2053417

Voltage: 120/240
 Amperage: 238
 Kilowatts: 57
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	411.2	411.4	411.7	411.9	412.2	412.3
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	240	240	240	240	240	240
PH2	0	0	0	0	0	0
PH3	0	0	0	0	0	0
Amperage PH1	0	238	238	237	238	0
PH2	0	238	237	238	238	0
PH3	0	0	0	0	0	0
Kilowatts	0	57	57	57	57	0
Oil Pressure	77	72	67	63	62	65
Oil Temperature						
Coolant Temperature	170°F	176°F	176°F	176°F	176°F	171°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	36°F	36°F	37°F	37°F	37°F	37°F

Technician Signature: Randy Pool

Customer Signature: _____