



Customer: Central States Diesel Generators
 Address: 2001 S. Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847.997.8090

R#: 9002
 Test Date 2020.03.27

Engine Make/ Model: VOLVO TAD720GE
 Engine Spec/ Serial: 5310243186
 Unit Make/ Model: POWER PRO SDG125S
 Unit Spec/ Serial: 1266A60196

Voltage: 480
 Amperage: 188
 Kilowatts: 125
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4827.4	4827.7	4828.0	4828.2	4828.5	4828.7
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	482	481	481	481	481
PH2	481	481	480	480	480	480
PH3	482	482	482	482	482	482
Amperage PH1	69	149	150	150	150	0
PH2	68	150	149	149	149	0
PH3	69	150	150	150	150	0
Kilowatts	57	125	125	125	125	0
Oil Pressure	70	70	70	70	70	70
Oil Temperature						
Coolant Temperature	120°F	150°F	170°F	170°F	175°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage						
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	47°F	47°F	47°F	47°F	47°F	47°F

Technician Signature: Rudy Sanchez

Customer Signature: _____