



Customer: Central States Diesel Generators STK#2650  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9115  
 Test Date 4-22-20

Engine Make/ Model: Cummins KTA19-G4  
 Engine Spec/ Serial: 37199857  
 Unit Make/ Model: Cummins DFED-4963038  
 Unit Spec/ Serial: H010273626

Voltage: 277/480  
 Amperage: 601  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	853.5	853.7	854	854.2	854.5	854.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	480	480	480	480	481	481
PH2	480	480	480	480	480	480
PH3	480	480	480	480	480	480
Amperage PH1	0	601	600	601	600	0
PH2	0	600	601	600	601	0
PH3	0	600	601	601	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	95	85	75	68	68	70
Oil Temperature						
Coolant Temperature	175°F	178°F	178°F	178°F	178°F	177°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	39°F	39°F	39°F	39°F	40°F	40°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_