



Customer: Central States Diesel Generators STK#2653

Address: 2001 S Prairie Ave.

City/ State/ Zip Waukesha, WI 53189

Contact: Patrick Paden

Phone: 262-955-7655

R#: 9024

Test Date 4-03-20

Engine Make/ Model: GM 5.7L (PSI)

Engine Spec/ Serial: HDH57L0004210

Unit Make/ Model: Kohler 100REZGD

Unit Spec/ Serial: SGM32JT5Z

Voltage: 277/480

Amperage: 118

Kilowatts: 98

Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	68.5	68.7	69	69.2	69.5	69.6
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	476	477	476	476	477	476
PH2	483	483	482	483	482	483
PH3	482	482	483	482	483	482
Amperage PH1	0	116	117	116	116	0
PH2	0	117	117	117	116	0
PH3	0	118	117	117	117	0
Kilowatts	0	98	98	98	98	0
Oil Pressure	46	42	42	41	41	44
Oil Temperature						
Coolant Temperature	180°F	186°F	187°F	187°F	187°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	45°F	45°F	45°F	45°F	45°F	45°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_