



Customer: Central States Diesel Generators STK#2658  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9229  
 Test Date 5-6-20

Engine Make/ Model: Volvo TAD1641GE  
 Engine Spec/ Serial: 2016016849  
 Unit Make/ Model: Katolight D500FRV4  
 Unit Spec/ Serial: 138288-0407

Voltage: 277/480  
 Amperage: 752  
 Kilowatts: 500  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	526.7	526.9	527.2	527.5	527.7	527.8
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	480	480	480	480	481	481
PH2	481	481	481	481	481	481
PH3	480	480	480	480	480	480
Amperage PH1	0	601	600	601	600	0
PH2	0	600	601	600	601	0
PH3	0	600	601	601	601	0
Kilowatts	0	500	500	500	500	0
Oil Pressure	95	85	75	68	68	70
Oil Temperature						
Coolant Temperature	175°F	188°F	188°F	188°F	188°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28.3	28.3	28.3	28.3	28.3	28.3
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	40°F	40°F	40°F	41°F	41°F	41°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_