



Customer: Central States Diesel Generators STK#2659  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip: Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9122  
 Test Date: 4-24-20

Engine Make/ Model: Ford LSG-875  
 Engine Spec/ Serial: NFE00159  
 Unit Make/ Model: Olympian G100F1  
 Unit Spec/ Serial: NFE00159

Voltage: 277/480  
 Amperage: 150  
 Kilowatts: 100  
 Power Factor: 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	566	566	566	567	567	567
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	491	491	490	491	491	491
PH2	491	490	491	491	491	491
PH3	490	490	490	490	490	490
Amperage PH1	0	118	118	118	118	0
PH2	0	117	118	117	118	0
PH3	0	118	118	117	118	0
Kilowatts	0	100	100	100	100	0
Oil Pressure	65	60	55	55	55	57
Oil Temperature						
Coolant Temperature	185°F	195°F	195°F	197°F	197°F	188°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	40°F	40°F	40°F	40°F	41°F	41°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_