



Customer: Central States Diesel Generators STK#2660
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9180
 Test Date 5-1-20

Engine Make/ Model: John Deere 4045DF150
 Engine Spec/ Serial: PE4045D391029
 Unit Make/ Model: Energy Now SED40FRJ40
 Unit Spec/ Serial: 651965-101684-0804

Voltage: 277/480
 Amperage: 60
 Kilowatts: 40
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	121.8	122	122.3	122.5	122.8	122.9
Hertz/Cycles	60.1	60.1	60.1	60.1	60.1	60.1
Voltage PH1	483	483	484	483	483	483
PH2	484	484	483	484	484	484
PH3	483	482	482	482	483	483
Amperage PH1	0	48	48	48	48	0
PH2	0	48	49	48	48	0
PH3	0	48	48	48	49	0
Kilowatts	0	40	40	40	40	0
Oil Pressure	59	57	56	56	56	57
Oil Temperature						
Coolant Temperature	170°F	173°F	174°F	174°F	174°F	173°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.9	13.9	13.9	13.9	13.9	13.9
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	48°F	48°F	49°F	49°F	49°F	49°F

Technician Signature: Randy Pool

Customer Signature: _____