



Customer: Central States Diesel Generators STK#2663
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9285
 Test Date 5-20-20

Engine Make/ Model: Cummins NTA-855-G3
 Engine Spec/ Serial: 30351417
 Unit Make/ Model: Cummins 350DFCC
 Unit Spec/ Serial: Spec.74726L S/N C950570868

Voltage: 277/480
 Amperage: 241
 Kilowatts: 200
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	2201.3	2201.5	2201.8	2202	2202.3	2202.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	481	481	481	481	481	481
PH2	482	482	482	482	483	482
PH3	483	482	483	483	483	483
Amperage PH1	0	420	419	420	421	0
PH2	0	421	420	420	421	0
PH3	0	420	419	420	420	0
Kilowatts	0	350	350	350	350	0
Oil Pressure	45	40	35	35	35	36
Oil Temperature						
Coolant Temperature	180°F	183°F	183°F	183°F	183°F	182°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	28	28	28	28	28	28
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	60°F	60°F	60°F	60°F	61°F	61°F

Technician Signature: _____

Customer Signature: _____