



Customer: Central States Diesel Generators STK#2666  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 262-955-7655

R#: 9282  
 Test Date 6-26-20

Engine Make/ Model: Perkins England 2326/1800  
 Engine Spec/ Serial: AB37591\*U651664  
 Unit Make/ Model: AB Gensets 2D075PNBCU  
 Unit Spec/ Serial: 105856-01

Voltage: 120/208  
 Amperage: 208  
 Kilowatts: 75  
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	453.5	453.8	454	454.3	454.5	454.6
Hertz/Cycles	61.9	60.1	60.1	60.1	60.1	61.9
Voltage PH1	209	209	209	209	209	209
PH2	208	208	208	208	208	208
PH3	209	208	209	209	209	209
Amperage PH1	0	207	208	208	208	0
PH2	0	208	208	208	207	0
PH3	0	208	207	208	208	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	46	43	42	42	42	44
Oil Temperature						
Coolant Temperature	180°F	187°F	188°F	188°F	188°F	184°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	74°F	74°F	74°F	74°F	75°F	75°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_