



Customer: Central States Diesel Generators STK#2667
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 847-997-8090

R#: 9283
 Test Date 5-21-2020

Engine Make/ Model: Perkins England 1004-4TG
 Engine Spec/ Serial: AB37591U631383L
 Unit Make/ Model: 2D075PNACU
 Unit Spec/ Serial: M04K066981-12

Voltage: 277/480
 Amperage: 91
 Kilowatts: 75
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	43.5	43.7	44	44.2	44.5	44.6
Hertz/Cycles	61.5	61	61	61	61	61.5
Voltage PH1	482	481	481	481	481	482
PH2	481	481	481	481	481	481
PH3	481	481	481	481	481	481
Amperage PH1	0	90	90	90	90	0
PH2	0	89	90	89	90	0
PH3	0	90	90	90	90	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	58	52	50	50	50	53
Oil Temperature						
Coolant Temperature	175°F	177°F	177°F	177°F	177°F	176°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	74°F	74°F	75°F	75°F	75°F	75°F

Technician Signature: Randy Pool

Customer Signature: _____