



Customer: Central States Diesel Generators STK#2668
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9660
 Test Date 9-3-20

Engine Make/ Model: Perkins 1004-40T
 Engine Spec/ Serial: AB37591U651655M
 Unit Make/ Model: AB Gensets 1D075PNBCU
 Unit Spec/ Serial: M05G080684-3

Voltage: 120/240 Single Phase
 Amperage: 313
 Kilowatts: 75
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	190.5	190.7	191	191.2	191.5	191.6
Hertz/Cycles	60	58.7	58.7	58.7	60	60
Voltage PH1	238	236	236	236	236	238
PH2	0	0	0	0	0	0
PH3	0	0	0	0	0	0
Amperage PH1	0	317	316	317	318	0
PH2	0	318	317	318	317	0
PH3	0	0	0	0	0	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	68	57	55	55	55	57
Oil Temperature						
Coolant Temperature	175°F	195°F	195°F	196°F	195°F	170°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14.1	14.1	14.1	14.1	14.1	14.1
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	76°F	76°F	76°F	76°F	77°F	77°F

Technician Signature: Randy Pool

Customer Signature: _____