



Customer: Central States Diesel Generators STK#2671  
 Address: 2001 S Prairie Ave.  
 City/ State/ Zip Waukesha, WI 53189  
 Contact: Patrick Paden  
 Phone: 847-997-8090

R#:  
 Test Date

Engine Make/ Model: Perkins England 1004-4TG  
 Engine Spec/ Serial: U649541M  
 Unit Make/ Model: 1D075PNBCU  
 Unit Spec/ Serial: 104278-01

Voltage: 120/240 sin  
 Amperage: 312  
 Kilowatts: 75  
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	136	136.2	136.5	136.7	137	137.1
Hertz/Cycles	61.5	60.2	60.2	60.2	60.2	61.5
Voltage PH1	242	242	242	242	242	242
PH2						
PH3						
Amperage PH1	0	310	311	309	310	0
PH2	0	311	310	310	311	0
PH3	0					0
Kilowatts	0	75	75	75	75	0
Oil Pressure	55	51	50	50	50	51
Oil Temperature						
Coolant Temperature	175°F	200°F	200°F	200°F	202°F	190°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	82°F	82°F	82°F	82°F	82°F	83°F

Technician Signature: Randy Pool

Customer Signature: \_\_\_\_\_