



Customer: Central States Diesel Generators STK#2672
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9258
 Test Date 5-14-20

Engine Make/ Model: Perkins 1004-40T
 Engine Spec/ Serial: AB375591*U652363M
 Unit Make/ Model: A B Gensets 10075PNBCU
 Unit Spec/ Serial: 104278-04

Voltage: 120/240
 Amperage: 312
 Kilowatts: 75
 Power Factor 1

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours		681.5	681.8	682	682.3	682.4
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	240	239	239	240	240	240
PH2						
PH3						
Amperage PH1	0	311	312	312	311	0
PH2	0	312	311	311	312	0
PH3	0	0	0	0	0	0
Kilowatts	0	75	75	75	75	0
Oil Pressure	60	53	51	51	51	53
Oil Temperature						
Coolant Temperature	185°F	190°F	189°F	190°F	190°F	185°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	14	14	14	14	14	14
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	47°F	47°F	48°F	48°F	48°F	49°F

Technician Signature: Randy Pool

Customer Signature: _____