



Customer: Central States Diesel Generators STK#2673
 Address: 2001 S Prairie Ave.
 City/ State/ Zip Waukesha, WI 53189
 Contact: Patrick Paden
 Phone: 262-955-7655

R#: 9355
 Test Date 6-1-20

Engine Make/ Model: PSI 8.8L
 Engine Spec/ Serial: 8.8L0013009
 Unit Make/ Model: Kohler 150REZGC
 Unit Spec/ Serial: 337DGMGC0002

Voltage: 120/208
 Amperage: 375 (test@80% rated)
 Kilowatts: 135
 Power Factor 0.8

	5 Min.	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	4.1	4.3	4.6	4.8	5.1	5.2
Hertz/Cycles	60	60	60	60	60	60
Voltage PH1	208	208	209	208	208	208
PH2	211	210	211	211	210	211
PH3	210	210	210	210	210	210
Amperage PH1	0	299	299	300	299	0
PH2	0	299	300	299	300	0
PH3	0	300	301	300	301	0
Kilowatts	0	109	109	109	109	0
Oil Pressure	52	45	45	44	44	47
Oil Temperature						
Coolant Temperature	160°F	165°F	165°F	165°F	165°F	164°F
Man Vac./Press. L/B						
Man Vac./Press. R/B						
L/B Exhaust Temp						
R/B Exhaust Temp						
Exhaust Temperature						
DC Voltage	13.8	13.8	13.8	13.8	13.8	13.8
Natural Gas Pressure						
Diesel Fuel Level						
Room Temperature						
Ambient Temperature	57°F	57°F	57°F	57°F	57°F	57°F

Technician Signature: Randy Pool

Customer Signature: _____